

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
AGD IX	AGD IX - 002.2024	2024-01-05	Escherichia coli (E. coli)	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-01-05	Bactérias coliformes	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-01-05	Desinfetante residual	=	0.6 mg/L
AGD IX	AGD IX - 001.2024	2024-02-27	Escherichia coli (E. coli)	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-02-27	Bactérias coliformes	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-02-27	Desinfetante residual	<	0.16 mg/L
AGD IX	AGD IX - 001.2024	2024-10-28	M656PH051	<	0.03 ug/L
AGD IX	AGD IX - 001.2024	2024-10-28	Dimetenamida-P	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Escherichia coli (E. coli)	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-05-07	Bactérias coliformes	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-05-07	Desinfetante residual	=	0.28 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cheiro a 25°C	<	1 Fator de diluição
AGD IX	AGD IX - 002.2024	2024-05-07	Sabor a 25°C	<	1 Fator de diluição
AGD IX	AGD IX - 002.2024	2024-05-07	pH	=	7 Unidades de pH
AGD IX	AGD IX - 002.2024	2024-05-07	Condutividade	=	206 uS/cm
AGD IX	AGD IX - 002.2024	2024-05-07	Cor	<	3 mg/L PtCo
AGD IX	AGD IX - 002.2024	2024-05-07	Turvação	<	1 UNT
AGD IX	AGD IX - 002.2024	2024-05-07	Enterococos	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-05-07	Número de colónias a 22 °C	=	0 N/mL
AGD IX	AGD IX - 002.2024	2024-05-07	Clostridium perfringens	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-05-07	Alumínio	<	10 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Amónio	<	0.05 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Antimónio	<	1 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Arsénio	<	3 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Benzeno	<	0.2 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Benzo(a)pireno	<	0.003 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Boro	<	0.01 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Bromatos	<	5 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cádmio	=	0.1 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cálcio	=	3.8 mg/L Ca
AGD IX	AGD IX - 002.2024	2024-05-07	Cianetos	<	10 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cloretos	<	10 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cloritos	<	0.02 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cloratos	<	0.08 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Chumbo	=	1 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Cobre	=	0.03 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Crómio	<	3 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	1,2 – dicloroetano	<	0.75 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Dureza total	=	19.5 mg/L Ca CO3
AGD IX	AGD IX - 002.2024	2024-05-07	Ferro	<	20 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Fluoretos	<	0.2 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Benzo(b)fluoranteno	<	0.02 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Benzo(k)fluoranteno	<	0.02 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Benzo(ghi) perileno	<	0.02 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Indeno(1,2,3-cd)pireno	<	0.02 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Magnésio	=	2.5 mg/L Mg
AGD IX	AGD IX - 002.2024	2024-05-07	Manganês	<	4 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Mercúrio	<	0.01 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Nitratos	=	1.6 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Nitritos	<	0.1 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Níquel	=	2.1 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Oxidabilidade	<	1 mg/L O2
AGD IX	AGD IX - 002.2024	2024-05-07	Potássio	<	2.5 mg/L K
AGD IX	AGD IX - 002.2024	2024-05-07	Selénio	<	2 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Sódio	=	31.5 mg/L

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
AGD IX	AGD IX - 002.2024	2024-05-07	Sulfatos	<	10 mg/L
AGD IX	AGD IX - 002.2024	2024-05-07	Tetracloroetano	<	0.2 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Tricloroetano	<	0.1 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Clorofórmio	=	0.41 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Bromofórmio	=	1.53 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Dibromoclorometano	=	0.86 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Bromodiclorometano	=	0.3 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Alfa total	=	0.08 Bq/L
AGD IX	AGD IX - 002.2024	2024-05-07	Dose indicativa	<	0.1 mSv
AGD IX	AGD IX - 002.2024	2024-05-07	Radão	=	17 Bq/L
AGD IX	AGD IX - 002.2024	2024-05-07	Urânio 234	=	NA Bq/L
AGD IX	AGD IX - 002.2024	2024-05-07	Urânio 238	=	NA Bq/L
AGD IX	AGD IX - 002.2024	2024-05-07	Rádio 226	=	NA Bq/L
AGD IX	AGD IX - 002.2024	2024-05-07	Polónio 210	=	NA Bq/L
AGD IX	AGD IX - 002.2024	2024-05-07	2,4-D	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Bentazona	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Clorpirifos	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Dimetoato	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Ometoato	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Diurão	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Imidaclopride	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	MCPA	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Metribuzina	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Metolaclo	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Terbutilazina	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Desetilterbutilazina	<	0.03 ug/L
AGD IX	AGD IX - 002.2024	2024-05-07	Oxadiazão	<	0.03 ug/L
AGD IX	AGD IX - 001.2024	2024-07-02	Escherichia coli (E. coli)	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-07-02	Bactérias coliformes	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-07-02	Desinfetante residual	=	0.7 mg/L
AGD IX	AGD IX - 002.2024	2024-08-27	Escherichia coli (E. coli)	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-08-27	Bactérias coliformes	=	0 N/100 mL
AGD IX	AGD IX - 002.2024	2024-08-27	Desinfetante residual	=	0.5 mg/L
AGD IX	AGD IX - 001.2024	2024-10-28	Escherichia coli (E. coli)	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-10-28	Bactérias coliformes	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-10-28	Desinfetante residual	=	0.4 mg/L
AGD IX	AGD IX - 001.2024	2024-10-28	Cheiro a 25°C	<	1 Fator de diluição
AGD IX	AGD IX - 001.2024	2024-10-28	Sabor a 25°C	<	1 Fator de diluição
AGD IX	AGD IX - 001.2024	2024-10-28	pH	=	7.6 Unidades de pH
AGD IX	AGD IX - 001.2024	2024-10-28	Condutividade	=	144 uS/cm
AGD IX	AGD IX - 001.2024	2024-10-28	Cor	<	3 mg/L PtCo
AGD IX	AGD IX - 001.2024	2024-10-28	Turvação	<	1 UNT
AGD IX	AGD IX - 001.2024	2024-10-28	Enterococos	=	0 N/100 mL
AGD IX	AGD IX - 001.2024	2024-10-28	Número de colónias a 22 °C	=	0 N/mL
AGD IX	AGD IX - 001.2024	2024-10-28	Ferro	<	60 ug/L