

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
ILH IV	ILH IV - 006.2024A	2024-01-17	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 006.2024A	2024-01-17	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 006.2024A	2024-01-17	Desinfetante residual	=	0.22 mg/L
ILH IV	ILH IV - 007.2024A	2024-02-14	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 007.2024A	2024-02-14	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 007.2024A	2024-02-14	Desinfetante residual	=	0.6 mg/L
ILH IV	ILH IV - 007.2024A	2024-02-14	Cheiro a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 007.2024A	2024-02-14	Sabor a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 007.2024A	2024-02-14	pH	=	8 Unidades de pH
ILH IV	ILH IV - 007.2024A	2024-02-14	Condutividade	=	424 uS/cm
ILH IV	ILH IV - 007.2024A	2024-02-14	Cor	<	3 mg/L PtCo
ILH IV	ILH IV - 007.2024A	2024-02-14	Turvação	<	1 UNT
ILH IV	ILH IV - 007.2024A	2024-02-14	Enterococos	=	0 N/100 mL
ILH IV	ILH IV - 007.2024A	2024-02-14	Número de colónias a 22 °C	=	0 N/mL
ILH IV	ILH IV - 007.2024A	2024-02-14	Clostridium perfringens	=	0 N/100 mL
ILH IV	ILH IV - 007.2024A	2024-02-14	Alumínio	<	10 ug/L
ILH IV	ILH IV - 007.2024A	2024-02-14	Ferro	=	214 ug/L
ILH IV	ILH IV - 007.2024A	2024-02-14	Manganês	<	4 ug/L
ILH IV	ILH IV - 002.2024	2024-03-13	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 002.2024	2024-03-13	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 002.2024	2024-03-13	Desinfetante residual	=	0.5 mg/L
ILH IV	ILH IV - 009.2024	2024-04-10	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 009.2024	2024-04-10	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 009.2024	2024-04-10	Desinfetante residual	=	0.4 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 001.2024	2024-05-08	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 001.2024	2024-05-08	Desinfetante residual	=	0.5 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cheiro a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 001.2024	2024-05-08	Sabor a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 001.2024	2024-05-08	pH	=	7.7 Unidades de pH
ILH IV	ILH IV - 001.2024	2024-05-08	Condutividade	=	443 uS/cm
ILH IV	ILH IV - 001.2024	2024-05-08	Cor	<	3 mg/L PtCo
ILH IV	ILH IV - 001.2024	2024-05-08	Turvação	<	1 UNT
ILH IV	ILH IV - 001.2024	2024-05-08	Enterococos	=	0 N/100 mL
ILH IV	ILH IV - 001.2024	2024-05-08	Número de colónias a 22 °C	=	0 N/mL
ILH IV	ILH IV - 001.2024	2024-05-08	Clostridium perfringens	=	0 N/100 mL
ILH IV	ILH IV - 001.2024	2024-05-08	Alumínio	<	10 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Amónio	<	0.05 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Antimónio	<	1 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Arsénio	<	3 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Benzeno	<	0.2 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Benzo(a)pireno	<	0.003 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Boro	=	0.066 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Bromatos	<	5 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cádmio	<	0.08 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cálcio	=	43.3 mg/L Ca
ILH IV	ILH IV - 001.2024	2024-05-08	Cianetos	<	10 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cloretos	=	28.4 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cloritos	<	0.02 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cloratos	<	0.08 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Chumbo	<	1 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Cobre	=	0.03 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Crómio	<	3 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	1,2 – dicloroetano	<	0.75 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Dureza total	=	135 mg/L Ca CO3

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
ILH IV	ILH IV - 001.2024	2024-05-08	Ferro	<	20 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Fluoretos	<	0.2 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Benzo(b)fluoranteno	<	0.02 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Benzo(k)fluoranteno	<	0.02 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Benzo(ghi) perileno	<	0.02 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Indeno(1,2,3-cd)pireno	<	0.02 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Magnésio	=	6.48 mg/L Mg
ILH IV	ILH IV - 001.2024	2024-05-08	Manganês	<	4 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Mercúrio	=	0.047 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Nitratos	=	42.6 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Nitritos	<	0.1 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Níquel	<	2 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Oxidabilidade	<	1 mg/L O2
ILH IV	ILH IV - 001.2024	2024-05-08	Potássio	=	4.7 mg/L K
ILH IV	ILH IV - 001.2024	2024-05-08	Selénio	<	2 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Sódio	=	41.1 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Sulfatos	<	10 mg/L
ILH IV	ILH IV - 001.2024	2024-05-08	Tetracloroetano	<	0.2 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Tricloroetano	<	0.1 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Clorofórmio	=	0.26 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Bromofórmio	=	0.84 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Dibromoclorometano	=	0.57 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Bromodiclorometano	=	0.24 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Alfa total	=	0.28 Bq/L
ILH IV	ILH IV - 001.2024	2024-05-08	Dose indicativa	<	0,1 mSv
ILH IV	ILH IV - 001.2024	2024-05-08	Rádio 226	=	0.11 Bq/L
ILH IV	ILH IV - 001.2024	2024-05-08	2,4-D	<	0,03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Bentazona	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Clorpirifos	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Ometoato	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Dimetoato	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Diurão	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Imidaclopride	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	MCPA	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Metribuzina	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Metolaclo-ro	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Terbutilazina	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Desetilterbutilazina	<	0.03 ug/L
ILH IV	ILH IV - 001.2024	2024-05-08	Oxadiazão	<	0,03 ug/L
ILH IV	ILH IV - 003.2024	2024-08-14	M656PH051	<	0.03 ug/L
ILH IV	ILH IV - 003.2024	2024-08-14	Dimetenamida-P	<	0.03 ug/L
ILH IV	ILH IV - 008.2024	2024-06-12	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 008.2024	2024-06-12	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 008.2024	2024-06-12	Desinfetante residual	=	0.5 mg/L
ILH IV	ILH IV - 005.2024	2024-07-10	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 005.2024	2024-07-10	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 005.2024	2024-07-10	Desinfetante residual	=	0.5 mg/L
ILH IV	ILH IV - 003.2024	2024-08-14	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 003.2024	2024-08-14	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 003.2024	2024-08-14	Desinfetante residual	=	0.4 mg/L
ILH IV	ILH IV - 003.2024	2024-08-14	Cheiro a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 003.2024	2024-08-14	Sabor a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 003.2024	2024-08-14	pH	=	7.8 Unidades de pH
ILH IV	ILH IV - 003.2024	2024-08-14	Condutividade	=	404 uS/cm
ILH IV	ILH IV - 003.2024	2024-08-14	Cor	<	3 mg/L PtCo

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
ILH IV	ILH IV - 003.2024	2024-08-14	Turvação	<	1 UNT
ILH IV	ILH IV - 003.2024	2024-08-14	Enterococos	=	0 N/100 mL
ILH IV	ILH IV - 003.2024	2024-08-14	Número de colónias a 22 °C	=	0 N/mL
ILH IV	ILH IV - 003.2024	2024-08-14	Clostridium perfringens	=	0 N/100 mL
ILH IV	ILH IV - 003.2024	2024-08-14	Alumínio	<	5 ug/L
ILH IV	ILH IV - 003.2024	2024-08-14	Ferro	=	12.3 ug/L
ILH IV	ILH IV - 003.2024	2024-08-14	Manganês	=	1.51 ug/L
ILH IV	ILH IV - 004.2024	2024-09-13	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 004.2024	2024-09-13	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 004.2024	2024-09-13	Desinfetante residual	=	0.7 mg/L
ILH IV	ILH IV - 001.2024	2024-10-09	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 001.2024	2024-10-09	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 001.2024	2024-10-09	Desinfetante residual	=	0.28 mg/L
ILH IV	ILH IV - 009.2024	2024-11-06	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 009.2024	2024-11-06	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 009.2024	2024-11-06	Desinfetante residual	=	0.5 mg/L
ILH IV	ILH IV - 009.2024	2024-11-06	Cheiro a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 009.2024	2024-11-06	Sabor a 25°C	<	1 Fator de diluição
ILH IV	ILH IV - 009.2024	2024-11-06	pH	=	6.8 Unidades de pH
ILH IV	ILH IV - 009.2024	2024-11-06	Condutividade	=	407 uS/cm
ILH IV	ILH IV - 009.2024	2024-11-06	Cor	<	3 mg/L PtCo
ILH IV	ILH IV - 009.2024	2024-11-06	Turvação	<	1 UNT
ILH IV	ILH IV - 009.2024	2024-11-06	Enterococos	=	0 N/100 mL
ILH IV	ILH IV - 009.2024	2024-11-06	Número de colónias a 22 °C	=	0 N/mL
ILH IV	ILH IV - 009.2024	2024-11-06	Clostridium perfringens	=	0 N/100 mL
ILH IV	ILH IV - 009.2024	2024-11-06	Alumínio	<	20 ug/L
ILH IV	ILH IV - 009.2024	2024-11-06	Ferro	<	60 ug/L
ILH IV	ILH IV - 009.2024	2024-11-06	Manganês	=	9.14 ug/L
ILH IV	ILH IV - 002.2024	2024-12-04	Escherichia coli (E. coli)	=	0 N/100 mL
ILH IV	ILH IV - 002.2024	2024-12-04	Bactérias coliformes	=	0 N/100 mL
ILH IV	ILH IV - 002.2024	2024-12-04	Desinfetante residual	=	0.5 mg/L