

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
SVV XIV	SVV XIV - 002.2024	2024-02-20	Escherichia coli (E. coli)	=	0 N/100 mL
SVV XIV	SVV XIV - 002.2024	2024-02-20	Bactérias coliformes	=	0 N/100 mL
SVV XIV	SVV XIV - 002.2024	2024-02-20	Desinfetante residual	=	0.38 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Escherichia coli (E. coli)	=	0 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-04-23	Bactérias coliformes	=	63 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-04-23	Desinfetante residual	=	0.5 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cheiro a 25°C	<	1 Fator de diluição
SVV XIV	SVV XIV - 004.2024	2024-04-23	Sabor a 25°C	<	1 Fator de diluição
SVV XIV	SVV XIV - 004.2024	2024-04-23	pH	=	7.5 Unidades de pH
SVV XIV	SVV XIV - 004.2024	2024-04-23	Condutividade	=	155 uS/cm
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cor	=	3.5 mg/L PtCo
SVV XIV	SVV XIV - 004.2024	2024-04-23	Turvação	<	1 UNT
SVV XIV	SVV XIV - 004.2024	2024-04-23	Enterococos	=	0 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-04-23	Número de colónias a 22 °C	=	7 N/mL
SVV XIV	SVV XIV - 004.2024	2024-04-23	Clostridium perfringens	=	0 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-04-23	Alumínio	<	10 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Amónio	<	0.05 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Antimónio	<	1 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Arsénio	<	3 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Benzeno	<	0.2 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Benzo(a)pireno	<	0.003 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Boro	<	0.01 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Bromatos	<	5 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cádmio	<	0.08 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cálcio	<	2.5 mg/L Ca
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cianetos	<	10 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cloretos	=	27.9 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cloritos	<	0.02 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cloratos	<	0.08 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Chumbo	<	1 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Cobre	<	0.003 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Crómio	<	3 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	1,2 – dicloroetano	<	0.75 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Dureza total	<	3 mg/L Ca CO3
SVV XIV	SVV XIV - 004.2024	2024-04-23	Ferro	<	20 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Fluoretos	<	0.2 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Benzo(b)fluoranteno	<	0.02 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Benzo(k)fluoranteno	<	0.02 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Benzo(ghi) perileno	<	0.02 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Indeno(1,2,3-cd)pireno	<	0.02 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Magnésio	<	0.25 mg/L Mg
SVV XIV	SVV XIV - 004.2024	2024-04-23	Manganês	<	4 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Mercúrio	<	0.01 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Nitratos	<	1 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Nitritos	<	0.1 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Níquel	<	2 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Oxidabilidade	=	1.3 mg/L O2
SVV XIV	SVV XIV - 004.2024	2024-04-23	Potássio	<	2.5 mg/L K
SVV XIV	SVV XIV - 004.2024	2024-04-23	Selénio	<	2 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Sódio	=	35.8 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Sulfatos	<	10 mg/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Tetracloroetano	<	0.2 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Tricloroetano	<	0.1 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Clorofórmio	=	22 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Bromofórmio	=	1.44 ug/L

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
SVV XIV	SVV XIV - 004.2024	2024-04-23	Dibromoclorometano	=	4.72 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Bromodiclorometano	=	9.34 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Alfa total	<	0.04 Bq/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Dose indicativa	<	0.1 mSv
SVV XIV	SVV XIV - 004.2024	2024-04-23	Radão	=	41,4 Bq/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Urânio 234	=	NA Bq/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Urânio 238	=	NA Bq/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Rádio 226	=	NA Bq/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Polónio 210	=	NA Bq/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	2,4-D	<	0,03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Bentazona	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Clorpirifos	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Ometoato	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Dimetoato	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Diurão	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-10-23	M656PH051	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-10-23	Dimetenamida-P	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Imidaclopride	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	MCPA	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Metribuzina	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Metolacoloro	<	0.01 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Terbutilazina	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Desetilterbutilazina	<	0.03 ug/L
SVV XIV	SVV XIV - 004.2024	2024-04-23	Oxadiazão	<	0,03 ug/L
SVV XIV	SVV XIV - 003.2024A	2024-06-25	Escherichia coli (E. coli)	=	0 N/100 mL
SVV XIV	SVV XIV - 003.2024A	2024-06-25	Bactérias coliformes	=	0 N/100 mL
SVV XIV	SVV XIV - 003.2024A	2024-06-25	Desinfetante residual	=	0.5 mg/L
SVV XIV	SVV XIV - 003.2024A	2024-08-23	Escherichia coli (E. coli)	=	0 N/100 mL
SVV XIV	SVV XIV - 003.2024A	2024-08-23	Bactérias coliformes	=	0 N/100 mL
SVV XIV	SVV XIV - 003.2024A	2024-08-23	Desinfetante residual	=	0.2 mg/L
SVV XIV	SVV XIV - 004.2024	2024-10-23	Escherichia coli (E. coli)	=	0 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-10-23	Bactérias coliformes	=	2 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-10-23	Desinfetante residual	=	0.34 mg/L
SVV XIV	SVV XIV - 004.2024	2024-10-23	Cheiro a 25°C	<	1 Fator de diluição
SVV XIV	SVV XIV - 004.2024	2024-10-23	Sabor a 25°C	<	1 Fator de diluição
SVV XIV	SVV XIV - 004.2024	2024-10-23	pH	=	7 Unidades de pH
SVV XIV	SVV XIV - 004.2024	2024-10-23	Condutividade	=	102 uS/cm
SVV XIV	SVV XIV - 004.2024	2024-10-23	Cor	<	3 mg/L PtCo
SVV XIV	SVV XIV - 004.2024	2024-10-23	Turvação	<	1 UNT
SVV XIV	SVV XIV - 004.2024	2024-10-23	Enterococos	=	0 N/100 mL
SVV XIV	SVV XIV - 004.2024	2024-10-23	Número de colónias a 22 °C	=	80 N/mL
SVV XIV	SVV XIV - 004.2024	2024-10-23	Manganês	=	6.56 ug/L
SVV XIV	SVV XIV - 002.2024	2024-12-26	Escherichia coli (E. coli)	=	0 N/100 mL
SVV XIV	SVV XIV - 002.2024	2024-12-26	Bactérias coliformes	=	0 N/100 mL
SVV XIV	SVV XIV - 002.2024	2024-12-26	Desinfetante residual	=	0.37 mg/L