

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
VGS IV	VGS IV - 002.2024	2024-01-10	Escherichia coli (E. coli)	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-01-10	Bactérias coliformes	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-01-10	Desinfetante residual	=	0.27 mg/L
VGS IV	VGS IV - 001.2024	2024-03-06	Escherichia coli (E. coli)	=	0 N/100 mL
VGS IV	VGS IV - 001.2024	2024-03-06	Bactérias coliformes	=	0 N/100 mL
VGS IV	VGS IV - 001.2024	2024-03-06	Desinfetante residual	=	0.32 mg/L
VGS IV	VGS IV - 001.2024	2024-11-06	M656PH051	<	0.03 ug/L
VGS IV	VGS IV - 001.2024	2024-11-06	Dimetenamida-P	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Escherichia coli (E. coli)	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-05-08	Bactérias coliformes	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-05-08	Desinfetante residual	=	0.25 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cheiro a 25°C	<	1 Fator de diluição
VGS IV	VGS IV - 002.2024	2024-05-08	Sabor a 25°C	<	1 Fator de diluição
VGS IV	VGS IV - 002.2024	2024-05-08	pH	=	7 Unidades de pH
VGS IV	VGS IV - 002.2024	2024-05-08	Condutividade	=	424 uS/cm
VGS IV	VGS IV - 002.2024	2024-05-08	Cor	<	3 mg/L PtCo
VGS IV	VGS IV - 002.2024	2024-05-08	Turvação	<	1 UNT
VGS IV	VGS IV - 002.2024	2024-05-08	Enterococos	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-05-08	Número de colónias a 22 °C	=	0 N/mL
VGS IV	VGS IV - 002.2024	2024-05-08	Clostridium perfringens	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-05-08	Alumínio	=	18.4 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Amónio	<	0.05 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Antimónio	<	1 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Arsénio	<	3 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Benzeno	<	0.2 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Benzo(a)pireno	<	0.003 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Boro	=	0.039 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Bromatos	<	5 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cádmio	<	0.08 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cálcio	=	35.9 mg/L Ca
VGS IV	VGS IV - 002.2024	2024-05-08	Cianetos	<	10 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cloreto	=	35.9 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cloritos	<	0.02 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cloratos	<	0.08 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Chumbo	<	1 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Cobre	=	0.014 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Crómio	<	3 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	1,2 – dicloroetano	<	0.75 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Dureza total	=	98 mg/L Ca CO3
VGS IV	VGS IV - 002.2024	2024-05-08	Ferro	<	20 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Fluoretos	<	0.2 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Benzo(b)fluoranteno	<	0.02 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Benzo(k)fluoranteno	<	0.02 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Benzo(ghi) perileno	<	0.02 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Indeno(1,2,3-cd)pireno	<	0.02 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Magnésio	=	9.3 mg/L Mg
VGS IV	VGS IV - 002.2024	2024-05-08	Manganês	=	4.7 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Mercúrio	=	0.126 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Nitratos	=	17.2 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Nitritos	<	0.1 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Níquel	<	2 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Oxidabilidade	<	1 mg/L O2
VGS IV	VGS IV - 002.2024	2024-05-08	Potássio	=	5.2 mg/L K
VGS IV	VGS IV - 002.2024	2024-05-08	Selénio	<	2 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Sódio	=	44.4 mg/L

Zona de Abastecimento	Ponto de Amostragem	Data de Amostragem	Parâmetro		Resultado
VGS IV	VGS IV - 002.2024	2024-05-08	Sulfatos	<	10 mg/L
VGS IV	VGS IV - 002.2024	2024-05-08	Tetracloroetano	<	0.2 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Tricloroetano	<	0.1 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Clorofórmio	=	0.76 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Bromofórmio	=	21.5 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Dibromoclorometano	=	7.76 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Bromodiclorometano	=	1.56 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Alfa total	=	0.07 Bq/L
VGS IV	VGS IV - 002.2024	2024-05-08	Dose indicativa	<	0.1 mSv
VGS IV	VGS IV - 002.2024	2024-05-08	Rádio 226	=	NA Bq/L
VGS IV	VGS IV - 002.2024	2024-05-08	2,4-D	<	0,03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Bentazona	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Clorpirifos	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Dimetoato	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Ometoato	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Diurão	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Imidaclopride	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	MCPA	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Metribuzina	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Metolaclo	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Terbutilazina	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Desetilterbutilazina	<	0.03 ug/L
VGS IV	VGS IV - 002.2024	2024-05-08	Oxadiazão	<	0,03 ug/L
VGS IV	VGS IV - 001.2024	2024-07-03	Escherichia coli (E. coli)	=	0 N/100 mL
VGS IV	VGS IV - 001.2024	2024-07-03	Bactérias coliformes	=	0 N/100 mL
VGS IV	VGS IV - 001.2024	2024-07-03	Desinfetante residual	=	0.5 mg/L
VGS IV	VGS IV - 002.2024	2024-09-04	Escherichia coli (E. coli)	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-09-04	Bactérias coliformes	=	0 N/100 mL
VGS IV	VGS IV - 002.2024	2024-09-04	Desinfetante residual	=	0.37 mg/L
VGS IV	VGS IV - 001.2024	2024-11-06	Escherichia coli (E. coli)	=	0 N/100 mL
VGS IV	VGS IV - 001.2024	2024-11-06	Bactérias coliformes	=	0 N/100 mL
VGS IV	VGS IV - 001.2024	2024-11-06	Desinfetante residual	=	0.5 mg/L